

**SECTION 00 11 15
ABBREVIATED SCOPE OF WORK**

THE FOLLOWING IS AN ABBREVIATED SCOPE OF WORK INTENDED TO PROVIDE POTENTIAL BIDDERS WITH INFORMATION AS TO THE SIZE AND NATURE OF THE PROJECT. BIDDERS ARE TO REFER TO THE DRAWINGS AND SPECIFICATIONS FOR THE COMPLETE SCOPE OF WORK.

**PROJECT: 22085.00 MIAMI CO SAFETY BUILDING CHILLER REPLACEMENT
201 W. MAIN STREET
TROY, OHIO 45373**

GMAE PROJECT NUMBER: 22085.00

BID DATE: NOVEMBER 17, 2022

BID CATEGORIES: LUMP SUM GENERAL CONTRACT

ESTIMATE OF CONSTRUCTION COST: \$440,000

PROJECT SCOPES OF WORK

2.01 HVAC WORK:

Includes installation of a new water cooled chiller in the basement of the Miami Co. Safety Building. Work shall include but not be limited to removal or existing chiller, installation of new chiller, removal and reconnections of existing evaporator and condenser piping to chiller, connecting temperatuer controls to chiller and configuring new chiller in control software. Removal of an abandoned generator and fuel oil piping is included as part of this project as well.

ELECTRICAL WORK:

The project will consist of providing electrical connection to new chiller.

END OF SECTION

This page intentionally left blank