

Addendum 02

DOCUMENT 00 9100

DATE: May 12, 2023

PROJECT: Hardin Hills Health Center Fire Pump Replacement
1211 Lima Street
Kenton, Ohio 43326

PROJECT #: 22083.00

OWNER: Board of Hardin County Commissioners
One Courthouse Square
Kenton, Ohio 43326

ARCHITECT: Garmann Miller
38 South Lincoln Drive
P.O. Box 71
Minster, Ohio 45865

TO: Prospective Bidders

This addendum form is a part of the Contract Documents and modifies the Bidding Documents dated April 18, 2023 with amendments and additions noted below.

Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may disqualify the Bidder.

This addendum consists of one page.

PRE-BID QUESTIONS- FOR INFORMATION ONLY

- Question:** In the corner of the existing pump room where it shows up coming in with a new supply line, there are some things coming up out of the floor. What are those and do they remain? Also, where we are coming into the pump room., are we in the underground water storage tank or under slab on grade?

Response: Per the owner, the flanged pipes in the corner of the room are abandoned pipes from discontinued wells. These are to be removed as needed for installation of the new fire pump, associated equipment, and piping. The existing size of the water storage tank is unknown. The final room layout and incoming water location will need field verified. Any modifications to the layout based on existing conditions will be reviewed during construction.

END OF ADDENDUM

