

# Addendum 02

DOCUMENT 00 91 00

**DATE:** January 30, 2026

**PROJECT:** Big Walnut Local School District  
Transportation Facility Lot Lighting  
117 N. Kitner Parkway  
Sunbury, Ohio 43074

**PROJECT #:** 25072.00

**OWNER:** Big Walnut LSD  
Contact: James Hall  
110 Tippett Ct.  
Sunbury, Ohio 43074

**ARCHITECT:** Garmann Miller  
38 South Lincoln Drive  
P.O. Box 71  
Minster, Ohio 45865

**TO:** Prospective Bidders

This addendum form is a part of the Contract Documents and modifies the Construction Documents dated January 14, 2026, with amendments and additions noted below.

Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may disqualify the Bidder.

This addendum consists of 2 pages.

## FOR INFORMATION ONLY

1. Bidding RFIs:
  - a. Question: Is THHN wire acceptable. General note K, on E1.2, calls out THHN, but the specs require XHHW-2 for underground wire.
    - i. Answer: Provide XHHW-2 type for underground as required per specifications. THHN is acceptable above ground.
  - b. Question: Is sch. 40 PVC acceptable for underground conduit? Or do we need sch 80?
    - i. Answer: Schedule 40 PVC is expected for conduit below grade per note L on the construction documents.



## **CHANGES TO THE PROJECT MANUAL**

1. N/A

## **CHANGES TO THE DRAWINGS**

1. N/A

## **ATTACHMENTS**

The following attachments are included and are part of this addendum: None

## **END OF ADDENDUM**

